

PUBLIC NOTICE:

On June 1st 2016, following a city-wide power outage on the evening of May 31, 2016, the City of Pembroke experienced a raw sewage spill of approximately 6,000 gallons from lift station #7 located on Harry Hagan Rd.

in Pembroke Ga. The spill entered an unnamed tributary of Mill Creek, and was a result of an electrical malfunction at the lift station. Immediately upon discovery of the malfunction the problem was corrected and the spill eliminated.